

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (800) 220-3675 / (856) 786-5974

<http://www.emsl.com>cinnaslab@EMSL.com

EMSL Order: 041308223

CustomerID: ENCC34

CustomerPO: Ravenna

ProjectID:

Attn: **Jackson Kiker**
Environmental Chemical Corporation
33 Boston Post Road West
Suite 420
Marlborough, MA 01752

Phone: (508) 229-6077
Fax:
Received: 04/04/13 9:20 AM
Analysis Date: 4/17/2013
Collected: 3/27/2013

Project: 5161.004 / Ravenna, Ohio

Test Report: Asbestos Analysis of Bulk Materials via EPA 600/R-93/116 and/or EPA 600/M4-82-020 Method(s) using Polarized Light Microscopy

Sample	Description	Appearance	<u>Non-Asbestos</u>		<u>Asbestos</u>
			% Fibrous	% Non-Fibrous	% Type
078TP-0033-0001-TP 041308223-0001	CC78.TP5	Brown Fibrous Homogeneous		80% Non-fibrous (other)	20% Chrysotile
078TP-0034-0001-TP 041308223-0002	CC78.TP5	Brown Fibrous Homogeneous		82% Non-fibrous (other)	18% Chrysotile

Analyst(s)

Brittany Brown (1)

Thomas Schwab (1)

Stephen Siegel, CIH, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government. Non-friable organically bound materials present a problem matrix and therefore EMSL recommends gravimetric reduction prior to analysis. Samples received in good condition unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request. Unless requested by the client, building materials manufactured with multiple layers (i.e. linoleum, wallboard, etc.) are reported as a single sample. Reporting limit is 1%

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ NVLAP Lab Code 101048-0, AIHA-LAP, LLC-IHLAP Lab 100194, NYS ELAP 10872, NJ DEP 03036

Initial report from 04/18/2013 00:15:05